Island County Water Well Information



General Information

Owner Name (log): R. P. Fakkema

DOE Tag: ALQ351 DOE NOI: DOE ID

Well Address: 1423' West & 410' North of East 1/4 378252

Well Parcel: R23307-360-3800

Served Parcel:

Horiz/Vert Accuracy: GPS / DEM

Site Type: Well USGS ID: 482147122355201 SWI Rating: Low Risk

Construction Information

Construction Date: Jun 1976

Driller Name: Whidbey Well Drillers (Faber)

LS Elevation: 234 ft. MSL

Depth Well: 249 ft.

TD Elevation: -15 ft. MSL

WL Measurements: 1 measurement (Click to View)

WL Elevation: 59 ft. MSL

Water Quality Information

Water Samples: 26 samples (Click to View)

Avg/Med/Max Arsenic: 0.004 / 0.005 / 0.005 mg/l

Avg/Med/Max Chloride: 34.34 / 21 / 80 mg/l

Avg/Med/Max Hardness: 132.83 / 150 / 160 mg/l

Avg/Med/Max Nitrate: 0.18 / 0.225 / 0.25 mg/l

Bacteria Samps (distribution): 345 samples (Click to View)

Click to View

Public Water System Information

Pws Name: Cedarhearth Water

PwsID: **96889**

Approved Connects: 24

Pws Source #: SO# 1

Pws Source Name: ALQ351 WELL 1

Note: <u>Underlined</u> items in **bright blue** are hyperlinks to additional information / resources. Questions? Contact the <u>Island County Hydrogeologist</u>, or visit the <u>Hydrogeology Web Page</u>.

Report Generated: 2/2/2021

Click to View
Well Location
in Google
Maps

Click to View
Well Location
in Google
Earth

Click to View

Scanned

Scanned

Report

-50/184 -100/134-150/84 -200/34

249/-15

Depth/ Elev(ft)

0/234